Apollosense [®]

Liquid Level Switches

Industrial Glass Tip Series; LLG810D3-003

- Liquid level switches that can detect almost any liquid type; oil or water based
- Suitable for harsh environments; robust stainless steel housing and glass tip
- Compact size
- Standard mounting thread; 1/2" NPT




- Suitable for use in high pressure applications
- Suitable for use in aggressive environments
- Direct load drive

XTECHNICAL SPECIFICATIONS

Supply voltage (Vs)	$4.5V_{\text{DC}}$ to $15.4V_{\text{DC}}$ (±5%)
Supply current (Is)	2.5mA max. (Vs = $15.4V_{DC}$)
Output sink and source current (lout)	1A
Operating temperature ¹	-40°C to +125°C
Operating pressure	0—85 bar
Housing material	Stainless steel housing with glass tip
Sensor termination	20AWG, 250mm PTFE wires, 8mm tinned

All dimensions shown in mm.



OUTPUT VALUES

 Output Voltage² (Vout):
 Iout = 1A

 Vs = 4.5—15.4V_{DC}
 Output High
 Vout = Vs - 1.5V max

 Output Low
 Vout = 0Vs + 0.5V max
 Vout = 0Vs + 0.5V max

Other sensor options available on request, email: sales@apollounion.com

Need help? Ask the expert 0755-83680810-819




深圳市新世联科技有限公司

地址: 深圳市深南中路2066号华能大厦712室 电话: 0755-83680810 83680820 83680830 83680860 网址: www.apollounion.com

邮编: 518031 传真: 0755-83680866 邮箱: sales@apollounion.com


Apollosense [®]

ELECTRICAL INTERFACE



CIRCUIT DIAGRAM





CAUTION: Take care when connecting loads. The minimum load impedance should not exceed Vs/max current.

Note: Shorting the output to Vs will result in irreparable damage to the sensor.

Recipications

	Description
Thread	1/2" NPT ¹
Pressure ²	85 bar maximum
Mounting Angle	Mount horizontally (0°) or up to 45° from horizontal (tip downwards) only
Tightening Torque ³	Hand-tighten, then torque one turn (maximum) past engagement

Notes:

- 1. NPT thread can be sealed with a curing type thread sealant such as "Loctite 565" with primer "N". Do not use PTFE tape.
- 2. When correctly sealed.
- 3. Do NOT over-tighten as this can permanently damage the sensor.

Specify the part number listed below when ordering.

L L G 8 1 0 D 3 - 0 0 3

CAUTION Do not exceed maximum ratings and ensure sensor(s) are operated in accordance with their requirements. Carefully follow all wiring instructions. Incorrect wiring can cause permanent damage to the device. SST Sensing Ltd recommend using Freon and alcohol based cleaning agents. Do NOT use chlorinated solvents auch as tricholerthane as these are likely to attack the sensor materials.	INFORMATION As customer applications are outside of SST Sensing Ltd.'s control, the information provided is given without legal responsibility. Customers should test under their own conditions to ensure that the equipment is suitable for their intended application. For technical assistance or advice, please email: sales@apollounion.com
Failure to comply with these instructions may result in product damage.	

General Note: SST Sensing Ltd. reserves the right to make changes to product specifications without notice or liability. All information is subject to SST Sensing Ltd.'s own data and considered accurate at time of going to print.

深圳市新世联科技有限公司

邮编: 518031 传真: 0755-83680866 邮箱: sales@apollounion.com